



MINIMUM ENVIRONMENTAL & ACCESSIBILITY REQUIREMENTS – REPAIRS AND RENEWALS

A. ENVIRONMENTAL EFFICIENCY REQUIREMENTS

Applicants must demonstrate that their repaired or renewed projects will achieve a minimum 25% reduction in energy use and Greenhouse Gas (GHG) emissions relative to pre-repair or pre-renewal (“based case”) performance.

Note: CMHC will prioritize applications that exceed the minimum requirements. Applicants should ensure that they clearly state if their projects will exceed the minimum requirements and by how much (e.g.; “...will exceed pre-repair or pre-renewal base case by 40%”).

Prior to Start of Repairs or Renewals, applicants must demonstrate:

- Compliance with energy and GHG emission reduction requirements through the submission of an analysis of the energy consumption and GHG emission performance of the base case building and the analysis of the energy consumption and GHG emission performance of the repaired or renewed project.
- The energy and GHG emission reduction analysis has been undertaken by a qualified professional. For Part 3 construction, this includes professionals with energy modelling experience such as a Professional Engineer, Architect, Certified Engineering Technologist (CET) or Certified Energy Manager (CEM). For low-rise (Part 9) single, semis, row houses, duplexes, triplexes and small multi-unit residential buildings with less than four storeys, a Residential Energy Advisor accredited by Natural Resources Canada, or equivalent, may undertake the analysis.
- An appropriate energy simulation software has been used to conduct the analysis. CanQuest and EnergyPlus are examples of accepted energy modelling software used for multi-unit residential buildings (Part 3 of the NBC). For buildings under Part 9 of NBC (low-rise buildings, townhomes), HOT2000 is acceptable software. Other software used must be approved by CMHC prior to the submission of the energy and GHG emission reduction analysis.
- The physical and operational characteristics of the pre-repair or renewal base case building and those of the proposed project that illustrate how the 25% energy and GHG emission reduction will be achieved.

- The required documentation to demonstrate compliance includes:
 - A brief Executive Summary of the comparison of annual total energy consumption and GHG emission reduction performance between the base case and the proposed repaired or renewed project.
 - A summary of the energy modelling of the proposed repaired or renewed project that indicates annual energy consumption and GHG emissions for the total building and a breakdown of the estimates for each major energy end use (e.g. space conditioning, hot water, lighting, equipment, appliances, etc.).
 - An overview of the key physical and operational features of the base case and proposed building that illustrates the improvements to be made to building envelope, space conditioning, hot water, lighting and other systems, energy recovery and renewable energy systems to achieve compliance.
 - Input and output files for the energy consumption modelling for the base case and proposed project. The files must detail monthly energy consumption for the whole building and by major end use (space heating, hot water, lighting, equipment, systems, etc.).
 - Any supplemental calculations for energy contributions of renewable energy systems, other systems and conditions not included in the energy and GHG modelling.
 - GHG calculations, methodology and assumptions.

Upon completion of the repair or renewal project:

Identify any changes to the repair or renewal plan. If there are significant changes that would have an impact on the energy consumption and GHG emissions of the project, an updated analysis will be required to be submitted to CMHC to confirm energy consumption and GHG emission reduction performance of the repaired or renewed project.

B. ACCESSIBILITY REQUIREMENTS

20% of dwelling units must meet accessibility standards (Table A) and common areas must be barrier-free (Table B)

Note:

1. CMHC will prioritize applications that exceed these minimum requirements. Applicants should ensure that they clearly state if their projects will exceed the minimum requirements and how.

Prior to the Repairs or Renewal:

- Indicate commitment to meeting the minimum requirement.
- Provide a narrative of the details of the proposed accessibility strategy within each unit and proposed barrier-free common areas.

At Repair/Renewal Completion

- Confirm the total number of accessible units provided and confirm that the accessibility features of the project comply with the application.
- Identify any changes that occurred to the repair or renewal project that would have impacted the accessibility plan and any impacts on the project eligibility (if applicable).

TABLE A

Technical Criteria for Accessible Dwelling Units

Note: Table incorporates key requirements only - source should be referenced for further detail as required.

Note: Unless noted otherwise, all dimensions are in millimeters.

INDEX

NHS = National Housing Strategy

BP = Better practice

CSA = CSA B651: Accessible design for the built environment

ID	Category	Sub-Category	Key Features	Source
A1	Application Criteria	Number of Units	20% of units to comply with accessibility standards	NHS
A2	Entrances and Doors	Entrance Landings	Min 1500 x 1500	CSA 7.4.1.5.1
A3	Entrances and Doors	Entrance Landings	Illuminated to at least 50 lx	CSA 7.4.1.5.1
A4	Entrances and Doors	Entrance Doors	No Step - Threshold no more than 13	CSA 7.4.1.5.2
A5	Entrances and Doors	Entrances and Doors	Motorized front entry doors to multi-unit buildings	CSA 7.4.1.5.2
A6	Entrances and Doors	Entrance Doors	Clear opening width of at least 810	CSA 7.4.1.5.2
A7	Entrances and Doors	Entrance Doors	Appropriate manoeuvring space either side	CSA 7.4.1.5.2
A8	Entrances and Doors	Entrance Doors	Appropriate hardware	CSA 7.4.1.5.2
A9	Entrances and Doors	Signage	Identification and numbers appropriately located and configured	CSA 7.4.1.5.3
A10	Entrances and Doors	Door Bells or Intercoms	Appropriately located and configured, including audible and visual signals	CSA 7.4.1.5.3
A11	Entrances and Doors	Door Viewers	Where installed, provide second viewer 1000-1200 high	CSA 7.4.1.5.5
A12	Interior Circulation	Corridors	At least 920 wide	CSA 7.4.2.1
A13	Interior Circulation	Corridors	No steps or changes in level	CSA 7.4.2.1
A14	Interior Circulation	Corridors	Surface stable, firm, slip-resistant, nominal glare, not heavily patterned	CSA 7.4.2.1
A15	Interior Circulation	Corridors	If carpet, low, firm and level pile or loop, carpet + pad max 13, securely fastened	CSA 7.4.2.1
A16	Interior Circulation	Doors and Doorways	Threshold no more than 13 - level threshold preferred including at balcony or patio doors	CSA 7.4.2.2
A17	Interior Circulation	Doors and Doorways	Clear opening width of at least 810	CSA 7.4.2.2

TABLE A (continued)

ID	Category	Sub-Category	Key Features	Source
A18	Interior Circulation	Doors and Doorways	Clear opening width of at least 850	BP
A19	Interior Circulation	Doors and Doorways	Appropriate manoeuvring space either side	CSA 7.4.2.2
A20	Interior Circulation	Doors and Doorways	Appropriate hardware	CSA 7.4.2.2
A21	Interior Circulation	Doors and Doorways	Doors to swing out (or be pocket doors) at bathroom/ washroom, roll-in closets and general storage	CSA 7.4.2.2
A22	Interior Circulation	Floor and wall Surfaces	No steps or changes in level	CSA 7.4.2.3
A23	Interior Circulation	Floor and wall Surfaces	Surface stable, firm, slip-resistant, nominal glare, not heavily patterned	CSA 7.4.2.3
A24	Interior Circulation	Floor and Wall Surfaces	If carpet, low, firm and level pile or loop, carpet + pad max 13, securely fastened	CSA 7.4.2.3
A25	Bathrooms	Floor Area	Provide 1500 diameter clear turn space or T-turn	BP
A26	Bathrooms	Lavatory	Clear floor space of at least 800 x 1350 (up to 480 may be under counter)	CSA 7.4.3.1
A27	Bathrooms	Lavatory	Centreline min 460 from side wall	CSA 7.4.3.1
A28	Bathrooms	Lavatory	Top 810-860 above the floor	CSA 7.4.3.1
A29	Bathrooms	Lavatory	Appropriate knee and toe space provided	CSA 7.4.3.1
A30	Bathrooms	Lavatory	Offset hot water pipes and drain (insulate if adjacent to knee and/or toe space)	CSA 7.4.3.1
A31	Bathrooms	Lavatory	Counter with front apron to have 750 wide x 720 high knee clearance	CSA 7.4.3.1
A32	Bathrooms	Lavatory	Appropriate faucet	CSA 7.4.3.1
A33	Bathrooms	Lavatory	Water temperature supply no more than 49 degrees Celsius	CSA 7.4.3.1
A34	Bathrooms	Medicine Cabinets	Adjacent to 750 x 1200 clear floor space with horizontal reach max 500	CSA 7.4.3.2
A35	Bathrooms	Medicine Cabinets	Bottom shelf max 1000 high	CSA 7.4.3.2
A36	Bathrooms	Medicine Cabinets	Appropriate door hardware	CSA 7.4.3.2
A37	Bathrooms	Medicine Cabinets	Illuminated to at least 200 lx	CSA 7.4.3.2
A38	Bathrooms	Storage	A shelf shall be provided, located max 1100	CSA 7.4.3.3
A39	Bathrooms	Towel Bars	Max 1100 high	CSA 7.4.3.4
A40	Bathrooms	Mirrors	Bottom edge no higher than 1000	CSA 7.4.3.5
A41	Bathrooms	Toilets	Seat not spring activated, height 430-485, back support where no seat lid or tank	CSA 7.4.3.6
A42	Bathrooms	Toilets	Centre line of toilet fixture 460-480 from an adjacent wall	CSA 7.4.3.6
A43	Bathrooms	Toilets	Clear transfer space of at least 900 wide x 1500 long on open side of toilet	CSA 7.4.3.6
A44	Bathrooms	Toilets	Automatic flush controls or appropriately configured hand-operated device	CSA 7.4.3.6

TABLE A (continued)

ID	Category	Sub-Category	Key Features	Source
A45	Bathrooms	Toilet - Struct. Support	Provide appropriate structural support for grab bars in walls around toilet	CSA 7.4.3.7
A46	Bathrooms	Toilet Paper Dispenser	Provide dispenser within 300 from front of toilet and 600-800 high	CSA 7.4.3.8
A47	Bathrooms	Bathtub	At least 1500 long	CSA 7.4.3.9
A48	Bathrooms	Bathtub	Clear floor area at least 750 wide along full length of open side of the tub (no door)	CSA 7.4.3.9
A49	Bathrooms	Bathtub	Appropriate faucets and other controls	CSA 7.4.3.9
A50	Bathrooms	Bathtub	Appropriate hand-held showerhead	CSA 7.4.3.9
A51	Bathrooms	Bathtub	Water temperature supply no more than 49 degrees Celsius	CSA 7.4.3.9
A52	Bathrooms	Bathtub - Struct. Support	Provide appropriate structural support to ceiling and in the surrounding 3 walls	CSA 7.4.3.9
A53	Bathrooms	Shower Stall	Water temperature supply no more than 49 degrees Celsius	CSA 7.4.3.10
A54	Bathrooms	Shower Stall	Appropriate hand-held showerhead	CSA 7.4.3.10
A55	Bathrooms	Shower Stall	Doors or curtains do not obstruct access to controls or the transfer space	CSA 7.4.3.10
A56	Bathrooms	Shower Stall	Floors sloped minimally to provide positive drainage and slip-resistant when wet	CSA 7.4.3.10
A57	Bathrooms	Shower Stall	Interior clear area at least 900 x 1500	CSA 7.4.3.10
A58	Bathrooms	Shower Stall	Clear floor area in front of the shower entrance of at least 900 x 1500	CSA 7.4.3.10
A59	Bathrooms	Shower Stall	Appropriate faucets and other controls	CSA 7.4.3.10
A60	Bathrooms	Shower Stall	Appropriate threshold - no more than 13	CSA 7.4.3.10
A61	Bathrooms	Shower – Struct. Support	Provide appropriate structural support to ceiling and in the surrounding walls	CSA 7.4.3.10
A62	Kitchens	Floor Area	Clear floor area of at least 750 x 1200 in front of fixtures	CSA 7.4.4.1
A63	Kitchens	Floor Area	Clear floor area of at least 750 x 1200 at one side of open doors and drawers	CSA 7.4.4.1
A64	Kitchens	Counters	At least one counter: 760 wide x 600 deep area, 730-860 high, with knee clearance	CSA 7.4.4.2
A65	Kitchens	Counters	Accessible counter has electrical outlet at side or front	CSA 7.4.4.2
A66	Kitchens	Base Cabinets	Toe space at least 150 deep x 230 high	CSA 7.4.4.3
A67	Kitchens	Sinks	Clear floor space of at least 800 x 1350 (up to 480 may be under counter)	CSA 7.4.4.4
A68	Kitchens	Sinks	At least 460 from side wall	CSA 7.4.4.4
A69	Kitchens	Sinks	Rim 810 - 860 high	CSA 7.4.4.4
A70	Kitchens	Sinks	Appropriate knee and toe space below	CSA 7.4.4.4
A71	Kitchens	Sinks	Appropriate faucets	CSA 7.4.4.4
A72	Kitchens	Sinks	Offset hot water pipes and drain (insulate if adjacent to knee and/or toe space)	CSA 7.4.4.4
A73	Kitchens	Illumination	At least 300 lx at countertops	CSA 7.4.4.5

TABLE A (continued)

ID	Category	Sub-Category	Key Features	Source
A74	Kitchens	Illumination	At least 100 lx at switches and controls (200 lx where reading required)	CSA 7.4.4.5
A75	Kitchens	Cooktops	810 - 860 high	CSA 7.4.4.6
A76	Kitchens	Cooktops	Adjacent work surface at least 400 wide, at same height as cooktop	CSA 7.4.4.6
A77	Kitchens	Cooktops	Appropriate knee-clearance below (including insulation as needed)	CSA 7.4.4.6
A78	Kitchens	Cooktops	Clear floor space of at least 800 x 1350 (up to 480 may be under cooktop)	CSA 7.4.4.6
A79	Kitchens	Ovens	Appropriate controls, mounted on front panel, no more than 1200 high	CSA 7.4.4.7
A80	Kitchens	Ovens	At side opening oven, provide heat resistant shelf beside oven door or under oven	CSA 7.4.4.7
A81	Kitchens	Refrigerator	Self-defrosting freezer with freezer shelf space no more than 1100 high	CSA 7.4.4.8
A82	Kitchens	Kitchen Storage	At least one shelf in cupboards no more than 1100 high	CSA 7.4.4.9
A83	Kitchens	Kitchen Storage	D-type door pulls within 400 - 1200 reach range	CSA 7.4.4.9
A84	Bedrooms	Floor Area	Clear floor area of at least 750 x 1200 mm on at least two sides of the bed	CSA 7.4.5
A85	Bedrooms	Floor Area	Provide 1500 diam clear turn space or T-turn in bedroom	BP
A86	Other Rooms	Floor Area	Provide 1500 diameter turn space or T-turn	BP
A87	Other Rooms	Laundry	Provide front-loading appliances with accessible operating controls	CSA 7.4.6.6
A88	Other Rooms	Laundry	Clear floor area of at least 750 x 1200 at one side of open appliance doors	CSA 7.4.6.6
A89	Other Rooms	Laundry	Where provided, laundry tub should allow a side-approach in a wheelchair	CSA 7.4.6.6
A90	General	Emergency + Security Alarms	Provide both audible and visual signals	CSA 7.4.6.1
A91	General	Windows	Where intended for views, sill max 750 above floor	CSA 7.4.6.2
A92	General	Windows	Accessible opening and locking mechanisms	CSA 7.4.6.2
A93	General	Operating Controls	Clear floor space in front at least 1350 x 800, centred	CSA 7.4.6.3
A94	General	Operating Controls	Located 400 -1200 high	CSA 7.4.6.3
A95	General	Operating Controls	Operable using one closed fist, with max 22N force	CSA 7.4.6.3
A96	General	Operating Controls	Provide tactile and/or auditory info indicating function and position of control	CSA 7.4.6.3
A97	General	Operating Controls	Colour contrast with mounting surface	CSA 7.4.6.3
A98	General	Operating Controls	Illuminated to at least 100 lx, 200 lx where reading is required	CSA 7.4.6.3

TABLE A (continued)

ID	Category	Sub-Category	Key Features	Source
A99	General	Operating Controls	Where control has visual display, info should be supplemented with tactile/audio	CSA 7.4.6.3
A100	General	Clothes Closets	Clear floor area in front of at least 750 x 1200	CSA 7.4.6.4
A101	General	Clothes Closets	Clothes rail 1200 - 1400	CSA 7.4.6.4
A102	General	Clothes Closets	Where shelves are provided, 3 shelves within 400 -1200 reach range	CSA 7.4.6.4
A103	General	General Storage	Outward-swinging or pocket door	CSA 7.4.6.5
A104	General	General Storage	Electrical outlet in inside, close to door	CSA 7.4.6.5
A105	General	General Storage	Capable of being illuminated to at least 50 lx	CSA 7.4.6.5
A106	General	Outdoor Living Spaces	Located adjacent to an accessible route	CSA 7.4.7
A107	General	Outdoor Living Spaces	At least 1500 x 1500 in area with accessible surface	CSA 7.4.7
A108	General	Outdoor Living Spaces	Appropriate manoeuvring space at appropriately configured accessible door	CSA 7.4.7
A109	General	Outdoor Living Spaces	Capable of being illuminated to at least 50 lx	CSA 7.4.7
A110	General	Outdoor Living Spaces	No step, level threshold through doors	CSA 7.4.7

TABLE B

Technical Criteria for Barrier-Free Common Areas

Note: Table incorporates key requirements only - source should be referenced for further detail as required.

Note: Unless noted otherwise, all dimensions are in millimeters.

INDEX

NHS = National Housing Strategy

BP = Better practice

CSA = CSA B651: Accessible design for the built environment

ID	Category	Sub-Category	Key Features	Source
B1	Circulation	Parking	Where provided, Interior, exterior or covered parking: <ul style="list-style-type: none"> • Pedestrian routes to comply with CSA 9.2 • Signage to comply with CSA 9.4 • Designated parking spaces to comply with CSA 9.5 	CSA 7.4.1.1
B2	Circulation	Passenger Pick-up Areas	Where provided, passenger pick-up areas to comply with CSA 9.3	CSA 7.4.1.2
B3	Circulation	Exterior Routes	Minor changes in level: 0-6 may be vertical, 7-13 to be bevelled	CSA 7.4.1.3
B4	Circulation	Exterior Routes	Clear width of at least 1200	CSA 7.4.1.3
B5	Circulation	Exterior Routes	Stable, firm and slip resistant surfaces	CSA 7.4.1.3

TABLE B (continued)

ID	Category	Sub-Category	Key Features	Source
B6	Circulation	Exterior Routes	Level, or sloped no steeper than the ratio of 1:20 (5%)	CSA 7.4.1.3
B7	Circulation	Exterior Routes	Cross-slope no steeper than the ration of 1:50 (2%)	CSA 7.4.1.3
B8	Circulation	Exterior Routes	Edge protection provided at grade changes and other potential hazards	CSA 7.4.1.3
B9	Circulation	Ramps	Slopes steeper than the ratio of 1:20 (5%) to be designed as ramps	CSA 7.4.1.4.1
B10	Circulation	Ramps	No steeper that the ratio of 1:12 (8.3%)	CSA 7.4.1.4.1
B11	Circulation	Ramps	Cross slope ne steeper than the ratio of 1:50 (2%)	CSA 7.4.1.4.1
B12	Circulation	Ramps	Landings no more than 9000 apart	CSA 7.4.1.4.1
B13	Circulation	Ramps	At least 920 wide	CSA 7.4.1.4.1
B14	Circulation	Ramps	Landings at top, bottom and changes in direction. Min 1500 long x at least ramp width. Min 1500 x 1500 at doors.	CSA 7.4.1.4.1
B15	Circulation	Ramps	Appropriate handrails	CSA 7.4.1.4.1
B16	Circulation	Ramps	Appropriate edge protection	CSA 7.4.1.4.1
B17	Circulation	Ramps	Appropriate surfaces, including colour-contrast band at slope transitions	CSA 7.4.1.4.1
B18	Circulation	Stairs	Risers no more than 180 and treads no less than 280 deep	CSA 7.4.1.4.2
B19	Circulation	Stairs	Slip resistant	CSA 7.4.1.4.2
B20	Circulation	Stairs	No open risers	CSA 7.4.1.4.2
B21	Circulation	Stairs	Illuminated to at least 50 lx	CSA 7.4.1.4.2
B22	Circulation	Stairs	Colour-contrast band on nosings	CSA 7.4.1.4.2
B23	Circulation	Stairs	Tactile attention indicators at top of stairs	CSA 7.4.1.4.2
B24	Circulation	Stairs	Appropriate handrails	CSA 7.4.1.4.2
B25	Circulation	Stairs	Appropriate edge protection	CSA 7.4.1.4.2
B26	Circulation	Elevating Devices	Comply with: Appendix E of ASME A17.1/CSA-B44 for elevators and service lifts, or CAN/CSA-B335 for an elevating device	CSA 7.4.1.4.3
B27	Entrances and Doors	Entrance Landings	Min 1500 x 1500	CSA 7.4.1.5.1
B28	Entrances and Doors	Entrance Landings	Illuminated to at least 50 lx	CSA 7.4.1.5.1
B29	Entrances and Doors	Entrance Doors	No Step - Threshold no more than 13	CSA 7.4.1.5.2
B30	Entrances and Doors	Entrance Doors	Clear opening width of at least 810	CSA 7.4.1.5.2
B31	Entrances and Doors	Entrance Doors	Appropriate manoeuvring space either side	CSA 7.4.1.5.2
B32	Entrances and Doors	Entrance Doors	Appropriate hardware and motorized automatic front entry doors	CSA 7.4.1.5.2
B33	Entrances and Doors	Signage	Identification and numbers appropriately located and configured	CSA 7.4.1.5.3
B34	Entrances and Doors	Door Bells or Intercoms	Appropriately located and configured, including audible and visual signals	CSA 7.4.1.5.3

TABLE B (continued)

ID	Category	Sub-Category	Key Features	Source
B35	Entrances and Doors	Door Viewers	Where installed, provide second viewer 1000-1200 high	CSA 7.4.1.5.5
B36	Interior Circulation	Corridors	At least 920 wide	CSA 7.4.2.1
B37	Interior Circulation	Corridors	No steps or changes in level	CSA 7.4.2.1
B38	Interior Circulation	Corridors	Surface stable, firm, slip-resistant, nominal glare, not heavily patterned	CSA 7.4.2.1
B39	Interior Circulation	Corridors	If carpet, low, firm and level pile or loop, carpet + pad max 13, securely fastened	CSA 7.4.2.1
B40	Interior Circulation	Doors and Doorways	Threshold no more than 13 - level threshold preferred	CSA 7.4.2.2
B41	Interior Circulation	Doors and Doorways	Clear opening width of at least 810	CSA 7.4.2.2
B42	Interior Circulation	Doors and Doorways	Appropriate manoeuvring space either side	CSA 7.4.2.2
B43	Interior Circulation	Doors and Doorways	Appropriate hardware	CSA 7.4.2.2
B44	Interior Circulation	Doors and Doorways	Doors to swing out at bathroom/washroom, roll-in closets and general storage	CSA 7.4.2.2
B45	Interior Circulation	Floor and Wall Surfaces	No steps or changes in level	CSA 7.4.2.3
B46	Interior Circulation	Floor and Wall Surfaces	Surface stable, firm, slip-resistant, nominal glare, not heavily patterned	CSA 7.4.2.3
B47	Interior Circulation	Floor and Wall Surfaces	If carpet, low, firm and level pile or loop, carpet + pad max 13, securely fastened	CSA 7.4.2.3
B48	Washrooms	Public Washrooms	Multi-stalled public washrooms to comply with CSA 6.2	CSA 6.2
B49	Washrooms	Public Washrooms	Universal public washrooms to comply with CSA 6.3	CSA 6.3
B50	Washrooms	Public Washrooms	Public bathing facilities to comply with CSA 6.5	CSA 6.5
B51	General	Emergency/ Security Alarms	Provide both audible and visual signals	CSA 7.4.6.1
B52	General	Operating Controls	Clear floor space in front at least 1350 x 800, centred	CSA 7.4.6.3
B53	General	Operating Controls	Located 400 -1200 high	CSA 7.4.6.3
B54	General	Operating Controls	Operable using one closed fist, with max 22N force	CSA 7.4.6.3
B55	General	Operating Controls	Provide tactile and/or auditory info indicating function and position of control	CSA 7.4.6.3
B56	General	Operating Controls	Colour contrast with mounding surface	CSA 7.4.6.3
B57	General	Operating Controls	Illuminated to at least 100 lx, 200 lx where reading is required	CSA 7.4.6.3
B58	General	Operating Controls	Where control has visual display, info should be supplemented with tactile/audio	CSA 7.4.6.3

TABLE B (continued)

ID	Category	Sub-Category	Key Features	Source
B59	General	Outdoor Living Spaces	Located adjacent to an accessible route	CSA 7.4.7
B60	General	Outdoor Living Spaces	At least 1500 x 1500 in area with accessible surface	CSA 7.4.7
B61	General	Outdoor Living Spaces	Appropriate manoeuvring space at appropriately-configures accessible door	CSA 7.4.7
B62	General	Outdoor Living Spaces	Capable of being illuminated to at least 50 lx	CSA 7.4.7
B63	General	Outdoor Living Spaces	No step, level threshold through doors	CSA 7.4.7
B64	General	Public Amenities	Where amenity spaces are provided for the use or resident and their visitors (such as community rooms, hobby rooms, etc.), they shall be accessible to persons with disabilities	BP

